

Variabili PLC

NONAME

Nome	Tipo di dati	Indirizzo	Riten- zione	Visi- bile in HMI	Acces- sibile da HMI	Commento
 leggi_ingresso_0	Int	%IW64	False	True	True	
 System_Byte	Byte	%MB900	False	True	True	
 FirstScan	Bool	%M900.0	False	True	True	
 DiagStatusUpdate	Bool	%M900.1	False	True	True	
 AlwaysTRUE	Bool	%M900.2	False	True	True	
 AlwaysFALSE	Bool	%M900.3	False	True	True	
 Clock_Byte	Byte	%MB910	False	True	True	
 Clock_10Hz	Bool	%M910.0	False	True	True	
 Clock_5Hz	Bool	%M910.1	False	True	True	
 Clock_2.5Hz	Bool	%M910.2	False	True	True	
 Clock_2Hz	Bool	%M910.3	False	True	True	
 Clock_1.25Hz	Bool	%M910.4	False	True	True	
 Clock_1Hz	Bool	%M910.5	False	True	True	
 Clock_0.625Hz	Bool	%M910.6	False	True	True	
 Clock_0.5Hz	Bool	%M910.7	False	True	True	
 Lampada_liv_max	Bool	%Q0.0	False	True	True	
 lamapada_liv_min	Bool	%Q0.1	False	True	True	
 uscita analogica	Int	%QW80	False	True	True	
 EN_valore max di corrente	Bool	%M10.0	False	True	True	
 EN_val medio di corrente	Bool	%M10.1	False	True	True	
 EN_val_basso di corrente	Bool	%M10.2	False	True	True	
 EN_val min di corrente	Bool	%M10.4	False	True	True	
 valore max	Bool	%M20.3	False	True	True	
 liv_temperatura_var_REAL	Real	%MD164	False	True	True	
 liv_temperatura_val_NOR- MALIZZATO	Real	%MD264	False	True	True	
 Lampada_temp_media	Bool	%Q0.2	False	True	True	

Owner	Project name analogiche I_O - lettura temperatura		Date 27/03/2013
	Project Path C:\Users\plc\Desktop\TUTTO sulle ANALOGICHE\analogiche I_O - lettura temperatura		
Operator	Location		
Designed By	Description 1st		
Checked By	Description 2nd	Language it-IT	
Approved By	1st View	Version	Sheet 1 - 1